



Department of Public Works  
Engineering Division

December 16, 2024

CITY OF BERKELEY  
STRAWBERRY CREEK CULVERT MAINTENANCE PROJECT – PHASE 1  
SPECIFICATION NO. 25-11689-C  
**ADDENDUM NO. 4**

Dear Bidder:

The following amendments are hereby made to the subject documents:

**1. Specifications: Technical Provisions, Bid Item No. B-9 – Install Access Hatch at Roosevelt Avenue, Materials, Bullet Item 4 (Page C-21)**

Add the following text at the end of bullet item 4: **“Access hatch assembly shall include fall protection safety grate.”**

**2. Specifications: Technical Provisions, Bid Items Nos. A-30 & B-19 – Culvert Invert Fill, Measurement and Payment (Page C-26)**

Modify the “Culvert Invert Fill” measurement and payment paragraph as follows:

“The contract price paid per pound **of dry geopolymer mortar material** for “Culvert Invert Fill” includes full compensation for furnishing all labor, materials, tools, equipment, and incidentals, and for doing all the work involved in spot concrete repairs, complete in place, including, cleaning, preparation, and disposal, as shown on the Plans, as specified in the State Standard Specifications, General, Special, and Technical Provisions, and as directed by the Engineer.”

**3. Specifications: Technical Provisions, Install Geopolymer Lining Bid Items, Execution (Page C-34)**

Delete 2<sup>nd</sup> paragraph page C-34: ~~“Follow manufacturer’s recommended cure schedule in curing of the geopolymer liner. The material must be allowed to cure for a minimum of 2 hours or until the material has reached an initial set condition whichever is longer prior to the release of bypass or flow through the culvert.”~~

Replace with: **“Culvert bypass shall remain in place until the material has cured to an initial set condition per manufacturer’s recommendation and meets the passing criteria demonstrated in the chronic toxicity testing (i.e. cure times for sample with a “Pass” test result).”**

The Bid Opening time and date remain at 2:00 PM, Thursday, December 19, 2024. All other provisions of the contract documents shall remain the same. **Bidders shall submit a signed acknowledgment of Addendum No. 4 along with their Bidder's Proposal. Failure to do so may result in bid rejection.**

Sincerely,



Srinivas Muktevi  
Supervising Civil Engineer

**BIDDER'S ACKNOWLEDGEMENT:**

Name of Company: \_\_\_\_\_

Address, City, State, Zip: \_\_\_\_\_

Signature: \_\_\_\_\_

Title: \_\_\_\_\_

Print Name: \_\_\_\_\_

Date: \_\_\_\_\_